


# Reference Projects

Plants built by Hitachi Zosen since 2000

in chronological order



### CH, Enova Emmenspitz

Start of operation	2025	In construction
Combustion	Concept	Water-cooled Grate
	Fuel	
	Number of Lines	2
	Throughput per line	16.53 t/h
	Thermal power per line	53.72 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	66 t/h at 47 bar(a) and 420 °C



### GB, Slough Multifuel

Start of operation	2023	In construction
Combustion	Concept	Water-cooled Grate
	Fuel	
	Number of Lines	2
	Throughput per line	36.30 t/h
	Thermal power per line	100.8 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	111 t/h at 57 bar(a) and 417 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor
	Throughput per line	164'741 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	50.00 MW (gross)
	Output	Electrical Power




### RU, Moscow 4

Start of operation	2023	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	
	Number of Lines	3
	Throughput per line	32.89 t/h
	Thermal power per line	75.83 MW
Boiler	Concept	5-pass boiler
	Steam	95 t/h at 70 bar(a) and 430 °C
Flue gas treatment	Concept	Activated Carbon Entrainment, Fabric Filter, SNCR, Dry Sorption Reactor, Heat Exchanger
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	147'030 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	70.00 MW (gross)
	Output	Steam, Electrical Power



### RU, Moscow 3

Start of operation	2023	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	
	Number of Lines	3
	Throughput per line	32.89 t/h
	Thermal power per line	75.83 MW
Boiler	Concept	5-pass boiler
	Steam	95 t/h at 70 bar(a) and 430 °C
Flue gas treatment	Concept	Activated Carbon Entrainment, Fabric Filter, SNCR, Dry Sorption Reactor, Heat Exchanger
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	147'030 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	70.00 MW (gross)
	Output	Steam, Electrical Power




### FR, Brion

Start of operation	2023	In construction
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'493 m³
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm³/h
	Hourly Biomethane Production	300 Nm³/h
	Biomethane Usage	Biomethane for gas-grid injection



### RU, Moscow 2

Start of operation	2023	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	
	Number of Lines	3
	Throughput per line	32.89 t/h
	Thermal power per line	75.83 MW
Boiler	Concept	5-pass boiler
	Steam	95 t/h at 70 bar(a) and 430 °C
Flue gas treatment	Concept	Activated Carbon Entrainment, Fabric Filter, SNCR, Dry Sorption Reactor, Heat Exchanger
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	147'030 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	70.00 MW (gross)
	Output	Steam, Electrical Power




### DE, Zuffenhausen

Start of operation	2023	In construction
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	2'100 m <sup>3</sup>
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	35'000 t/a



### AE, Dubai WMC

Start of operation	2023	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	5
	Throughput per line	53.57 t/h
	Thermal power per line	124.6 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	170 t/h at 77 bar(a) and 432 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter
	Reactant	Activated Carbon, Calcium Hydroxide
Energy recovery	Throughput per line	234'064 m <sup>3</sup> /h (STP)
	Concept	Condensation Turbine
	Electric power output	214.6 MW (gross)
	Output	Electrical Power



### FR, Lierville

Start of operation	2022	In construction
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'493 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	700 Nm <sup>3</sup> /h
	Hourly Biomethane Production	350 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Ivry-sur-Seine

Start of operation	2022	In construction
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste, Refuse Derived Fuel
	Number of Lines	2
	Throughput per line	24.64 t/h
	Thermal power per line	75.55 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	92 t/h at 60 bar(a) and 420 °C




### AU, Rockingham

Start of operation	2022	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	41.18 t/h
	Thermal power per line	101.8 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	129 t/h at 66 bar(a) and 431 °C
Flue gas treatment	Concept	Dry Sorption Reactor, SNCR, Activated Carbon Entrainment, Fabric Filter
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	236'327 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	32.00 MW (gross)
	Output	Electrical Power




### GB, Newhurst

Start of operation	2022	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	50.93 t/h
	Thermal power per line	126.4 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	157 t/h at 80 bar(a) and 450 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SNCR
	Reactant	Activated Carbon, Calcium Hydroxide
	Throughput per line	239'250 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	43.30 MW (gross)
	Output	Electrical Power



### IT, Reggio Emilia

Start of operation	2022	In construction
Anaerobic Digestion	Number of Digester(s)	4
	Net volume per digester	2'100 m³
	Waste Throughput per Year	111'000 t/a
Gas Upgrading		




### US, Carpenter

Start of operation  
Gas Upgrading

2022  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
Membrane Technology  
Biogas from Agricultural Residues  
1'014 Nm<sup>3</sup>/h  
575 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection,  
CNG



### FR, Faremoutiers

Start of operation  
Anaerobic Digestion

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type

Gas Upgrading

Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
2  
2'493 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
600 Nm<sup>3</sup>/h  
300 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### RU, Moscow 1

Start of operation  
Combustion

2022  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line

Boiler

Concept  
Superheated Steam


Flue gas treatment

Concept

Energy recovery

Reactant  
Throughput per line  
Concept  
Electric power output  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
3  
32.89 t/h  
75.83 MW  
5-pass boiler  
95 t/h at 70 bar(a) and 430 °C  
Activated Carbon Entrainment,  
Fabric Filter, SNCR, Dry Sorption  
Reactor, Heat Exchanger  
Calcium Hydroxide, Lignite Coke  
147'030 m<sup>3</sup>/h (STP)  
Condensation Turbine  
70.00 MW (gross)  
Steam, Electrical Power



### FR, Missy-lès-Pierrepont


Start of operation  
Anaerobic Digestion

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type

Gas Upgrading

Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Voulton

Start of operation  
Anaerobic Digestion

Gas Upgrading

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### FR, Amillis

Start of operation  
Anaerobic Digestion

Gas Upgrading

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### FR, Saint-Martin-du-Boschet

Start of operation  
Anaerobic Digestion

Gas Upgrading

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
600 Nm<sup>3</sup>/h  
300 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### FR, Tremblay-les-Villages

Start of operation  
Anaerobic Digestion

Gas Upgrading

2022  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

In construction  
2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Saugnacq-et-Muret

Start of operation	2022	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Bellegarde-sur-Valserine Flue gas Treatment

Start of operation	2021	In construction
Flue gas treatment	Concept	Dry Sorption Reactor, Dry Sorption Reactor 2, Heat Exchanger, Heat exchanger 2, SCR
	Number of Lines	2
	Fuel	Municipal Solid Waste
	Reactant	Sodium Bicarbonate
	Throughput per line	50'000 m <sup>3</sup> /h (STP)



### FR, Vinantes

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	400 Nm <sup>3</sup> /h
	Hourly Biomethane Production	200 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Réau

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### DE, Kirchberg

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'050 m <sup>3</sup>
	Waste Throughput per Year	15'000 t/a




### GB, Rookery

Start of operation	2021	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	25.00 t/h
	Thermal power per line	64.58 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	82 t/h at 75 bar(a) and 440 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SNCR
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	117'000 m <sup>3</sup> /h (STP)




### FR, Mont-l'Évêque

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Chauconin-Neufmontiers

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Boutigny-sur-Essone

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
Gas Upgrading	Digester Type	Wet AD
	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Pouan-les-Vallées

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
Gas Upgrading	Digester Type	Wet AD
	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Trancault

Start of operation	2021	In construction
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
Gas Upgrading	Digester Type	Wet AD
	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### IT, Legnano

Start of operation	2021	In construction
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m <sup>3</sup>
Gas Upgrading	Waste Throughput per Year	40'500 t/a
	Plant Capacity	625 Nm <sup>3</sup> /h




### FR, Coulombs-en-Valois

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Avon-la-Pèze

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Saint-Jean-d'Illac

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Prémierfait

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Membrane Technology
Gas Upgrading	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Saint-Laurent-Médoc II

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### US, Escondido

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'100 m <sup>3</sup>
	Waste Type	Food Waste, Green Waste
	Waste Throughput per Year	84'400 t/a
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Green Waste & Bio Waste, Biogas from Energy Crops, Biogas from Agricultural Residues, Biogas from Source Separated Municipal Waste
	Plant Capacity	447 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### CN, Chongqing II

Start of operation	2021	In construction
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	2'100 m <sup>3</sup>
	Waste Throughput per Year	110'000 t/a




### FR, Bar-sur-Seine

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### FR, Saint-Mesmin

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Chapelle-Vallon

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### CN, Chongqing I

Start of operation	2021	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'800 m <sup>3</sup>
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	50'000 t/a



### CN, Nanjing

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'800 m <sup>3</sup>
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	55'000 t/a




### **CN, Hangzhou**

Start of operation

2020

In construction




### **SE, Momarken Torsvik**

Start of operation

2020

In construction



### **FR, Charny**

Start of operation

2020

Anaerobic Digestion

Number of Digester(s)

2

Net volume per digester

2'300 m<sup>3</sup>

Digester Type

Wet AD

Gas Upgrading

Technology

Membrane Technology

Input Gas

Biogas from Agricultural Residues

Plant Capacity

500 Nm<sup>3</sup>/h

Hourly Biomethane Production

250 Nm<sup>3</sup>/h

Biomethane Usage

Biomethane for gas-grid injection



### **FR, Saint-Germain**

Start of operation

2020

Anaerobic Digestion

Number of Digester(s)

2

Net volume per digester

2'300 m<sup>3</sup>

Digester Type

Wet AD

Gas Upgrading

Technology

Membrane Technology

Input Gas

Biogas from Agricultural Residues

Plant Capacity

400 Nm<sup>3</sup>/h

Hourly Biomethane Production

200 Nm<sup>3</sup>/h

Biomethane Usage

Biomethane for gas-grid injection




### FR, Les-Grandes-Chapelles

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### US, Escondido

Start of operation	2020	
Gas Upgrading	Technology	Membrane Technology
	Plant Capacity	1'000 Nm <sup>3</sup> /h
	Hourly Biomethane Production	500 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Herpy-l'Arlésienne

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	600 Nm <sup>3</sup> /h
	Hourly Biomethane Production	300 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### SE, Jönköping

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'500 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Grease sludge, Green Waste, Production Waste
Gas Upgrading	Waste Throughput per Year	40'000 t/a
	Technology	Membrane Technology
	Input Gas	Biogas from Green Waste & Bio Waste
	Plant Capacity	717 Nm <sup>3</sup> /h
	Hourly Biomethane Production	430 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane Filling Station, CNG



### FR, Trouy

Start of operation  
Anaerobic Digestion

Gas Upgrading

2020	1
Number of Digester(s)	2'300 m <sup>3</sup>
Net volume per digester	Wet AD
Digester Type	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	300 Nm <sup>3</sup> /h
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	



### FR, Yversay

Start of operation  
Anaerobic Digestion

Gas Upgrading

2020	2
Number of Digester(s)	2'300 m <sup>3</sup>
Net volume per digester	Wet AD
Digester Type	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	500 Nm <sup>3</sup> /h
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	




### FR, Neuville-Saint-Amand

Start of operation  
Anaerobic Digestion

Gas Upgrading

2020	2
Number of Digester(s)	2'300 m <sup>3</sup>
Net volume per digester	Wet AD
Digester Type	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	500 Nm <sup>3</sup> /h
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	



### FR, Bucy-le-Long

Start of operation  
Anaerobic Digestion


Gas Upgrading

2020	2
Number of Digester(s)	2'300 m <sup>3</sup>
Net volume per digester	Wet AD
Digester Type	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	500 Nm <sup>3</sup> /h
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	




### DE, Anröchte

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'500 m <sup>3</sup>
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	15'000 t/a



### JP, Mito, Ibaraki

Start of operation	2020	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	4.58 t/h



### JP, Yokosuka, Kanagawa

Start of operation	2020	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	5.00 t/h



### FR, Saint-Aubin

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Messy

Start of operation  
Anaerobic Digestion

Gas Upgrading

2020

Number of Digester(s)

Net volume per digester

Digester Type

Technology

Input Gas

Plant Capacity

Hourly Biomethane Production

Biomethane Usage

2

2'300 m<sup>3</sup>

Wet AD

Membrane Technology

Biogas from Agricultural Residues

600 Nm<sup>3</sup>/h

430 Nm<sup>3</sup>/h

Biomethane for gas-grid injection



### CA, London

Start of operation  
Gas Upgrading

2020

Technology

Input Gas

Plant Capacity

Hourly Biomethane Production

Biomethane Usage

Membrane Technology

Biogas from Green Waste & Bio Waste

1'200 Nm<sup>3</sup>/h

800 Nm<sup>3</sup>/h

Biomethane for gas-grid injection



### DK, Vrå

Start of operation  
Gas Upgrading

2020

Technology

Input Gas

Plant Capacity

Hourly Biomethane Production

Biomethane Usage


Membrane Technology

Biogas from Agricultural Residues

900 Nm<sup>3</sup>/h

500 Nm<sup>3</sup>/h

Biomethane for gas-grid injection



### GB, Aberdeenshire

Start of operation  
Gas Upgrading

2020

Technology

Input Gas

Plant Capacity

Hourly Biomethane Production

Biomethane Usage


Membrane Technology

Biogas from Green Waste & Bio Waste

1'200 Nm<sup>3</sup>/h

680 Nm<sup>3</sup>/h

Biomethane for gas-grid injection



### FR, Chalandry

Start of operation	2020	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### TR, Istanbul

Start of operation	2019	
Combustion	Concept	Air-cooled Grate
	Fuel	Hospital Waste, Municipal Solid Waste
	Number of Lines	3
	Throughput per line	46.00 t/h
	Thermal power per line	86.81 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	112 t/h at 72 bar(a) and 426 °C
Flue gas treatment	Concept	SNCR, Dry Sorption Reactor, Fabric Filter
	Reactant	Calcium Hydroxide, Activated Carbon
	Throughput per line	173'720 m <sup>3</sup> /h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	77.21 MW (gross)
	Output	Electrical Power



### FR, Saint-Laurent-Médoc

Start of operation	2019	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Payns

Start of operation	2019	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### **CN, Shunde**

Start of operation  
Combustion

Energy recovery

2019  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
4  
35.42 t/h  
Electrical Power




### **CN, Jimo**

Start of operation  
Combustion

2019  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
3  
12.50 t/h



### **CN, Tancheng**

Start of operation  
Combustion

2019  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
16.70 t/h



### **JP, Kyoto (Nambu No.2)**

Start of operation  
Combustion

Energy recovery

2019  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
10.42 t/h  
39.06 MW  
Electrical Power



### JP, Nagano, Nagano

Start of operation	2019	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	5.60 t/h
	Thermal power per line	17.90 MW
Energy recovery	Output	Electrical Power



### TH, WPP Phetchaburi

Start of operation	2019	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	19.83 t/h
Energy recovery	Output	Electrical Power



### GR, Epirus

Start of operation	2019	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'500 m <sup>3</sup>
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	38'700 t/a



### GB, Ferrybridge Multifuel 2 (FM2)

Start of operation	2019	Water-cooled Grate
Combustion	Concept	Municipal Solid Waste, Refuse
	Fuel	Derived Fuel
	Number of Lines	2
	Throughput per line	42.26 t/h
	Thermal power per line	117.7 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	145 t/h at 73 bar(a) and 430 °C
Flue gas treatment	Concept	Fabric Filter, SNCR, Semi-dry Reactor
	Reactant	Activated Carbon, Calcium Hydroxide
Energy recovery	Throughput per line	238'866 m <sup>3</sup> /h (STP)
	Concept	Condensation Turbine
	Electric power output	79.17 MW (gross)
	Output	Electrical Power



### DE, Hamburg

Start of operation  
Gas Upgrading

2019  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Sewage Sludge  
1'500 Nm<sup>3</sup>/h  
930 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### GB, Edinburgh

Start of operation  
Combustion

2018  
Concept  
Fuel

Boiler

Number of Lines  
Throughput per line  
Thermal power per line

Flue gas treatment

Concept  
Superheated Steam  
Concept  
Reactant

Energy recovery

Throughput per line  
Concept  
Electric power output  
Output

Air-cooled Grate  
Municipal Solid Waste, Refuse  
Derived Fuel  
1  
24.00 t/h  
50.00 MW  
6-pass boiler  
64 t/h at 60 bar(a) and 400 °C  
Dry Sorption Reactor, Fabric Filter  
Calcium Hydroxide, Activated  
Carbon  
103'178 m<sup>3</sup>/h (STP)  
Condensation Turbine  
12.49 MW (gross)  
Electrical Power



### CN, Changsha

Start of operation  
Combustion

2018  
Concept  
Fuel

Energy recovery

Number of Lines  
Throughput per line  
Output

In construction  
Air-cooled Grate  
Refuse Derived Fuel, Municipal  
Solid Waste  
6  
35.42 t/h  
Electrical Power



### CN, Laohuchong

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
4  
31.25 t/h



### JP, Kyoto 2

Start of operation  
Anaerobic Digestion


2018	In construction
Number of Digester(s)	2
Net volume per digester	1'483 m <sup>3</sup>
Waste Type	Organic Fraction of Municipal Solid Waste
Waste Throughput per Year	20'820 t/a



### IT, Foligno

Start of operation  
Anaerobic Digestion

2018	
Number of Digester(s)	2
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	40'000 t/a



### CN, Rénhuái

Start of operation  
Combustion

2018	In construction
Concept	Air-cooled Grate
Fuel	Municipal Solid Waste
Number of Lines	2
Throughput per line	25.00 t/h



### FR, Combrand

Start of operation  
Anaerobic Digestion

2018	
Number of Digester(s)	3
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Solid Manure, Crop Residues
Waste Throughput per Year	46'000 t/a



### US, San Luis Obispo

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'800 m <sup>3</sup>
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	30'000 t/a




### IT, Bologna

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	4
	Net volume per digester	1'800 m <sup>3</sup>
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	102'000 t/a



### SE, Högbytorp

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	2'100 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Green Waste, Solid Manure
	Waste Throughput per Year	83'050 t/a



### TH, Nong Khai

Start of operation	2018	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	15.42 t/h
Energy recovery	Output	Electrical Power



### JP, Orii

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
2.40 t/h



### JP, Yatsushiro, Kumamoto

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Electric power output  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
2.79 t/h  
9.93 MW  
Condensation Turbine  
2.88 MW (gross)  
Electrical Power



### JP, Neyagawa

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
4.17 t/h  
13.60 MW  
Dry Sorption Reactor, Fabric  
Filter, SCR  
Calcium Hydroxide, Activated  
Carbon  
23'990 m³/h (STP)  
Electrical Power

Flue gas treatment

Reactant

Energy recovery

Throughput per line  
Output




### CN, Pingxiang

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
16.70 t/h




### **CN, Nínghé**

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
20.83 t/h




### **MY, SMART WTE**

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Energy recovery  
Concept  
Electric power output  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
25.00 t/h  
69.44 MW  
Condensation Turbine  
17.70 MW (gross)  
Electrical Power




### **CN, Déyáng**

Start of operation  
Combustion

2018  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
50.00 t/h



### **SE, Högbyporp (Residue Treatment)**

Start of operation

2018



### FR, Audenge

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Cernay

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Fère-Champenoise

Start of operation	2018	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
	Digester Type	Wet AD
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### DE, Grabsleben II

Start of operation	2018	In construction
Gas Upgrading	Technology	Amine Scrubbing
	Input Gas	Biogas from Energy Crops
	Plant Capacity	700 Nm <sup>3</sup> /h
	Hourly Biomethane Production	350 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### DE, Parum

Start of operation  
Gas Upgrading

2018

Technology  
Input Gas

Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Green Waste & Bio Waste  
700 Nm<sup>3</sup>/h  
400 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Plaidt

Start of operation  
Gas Upgrading

2018

Technology  
Input Gas

Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Green Waste & Bio Waste  
500 Nm<sup>3</sup>/h  
300 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Pommeuse

Start of operation  
Anaerobic Digestion

2018

Number of Digester(s)  
Net volume per digester  
Digester Type

2  
2'300 m<sup>3</sup>  
Wet AD

Gas Upgrading

Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Saconin

Start of operation  
Anaerobic Digestion

2018

Number of Digester(s)  
Net volume per digester  
Digester Type

2  
2'300 m<sup>3</sup>  
Wet AD

Gas Upgrading

Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



**CN, Ningbo**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
3  
31.25 t/h



**CN, Huairou**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h




**CN, Chengdu Wanxing**

Start of operation  
Combustion

Energy recovery

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
4  
25.00 t/h  
48.60 MW  
Electrical Power



**DE, Herten**

Start of operation

2017



### **CN, Yulin**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
16.67 t/h



### **JP, Joetsu, Niigata**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line

Flue gas treatment

Concept

Reactant

Energy recovery

Throughput per line  
Output

In construction  
Water-cooled Grate  
Municipal Solid Waste  
2  
3.54 t/h  
15.60 MW  
SNCR, Dry Sorption Reactor,  
Fabric Filter  
Calcium Hydroxide, Activated  
Carbon  
20'330 m³/h (STP)  
Hot Water, Electrical Power



### **CN, Bazhou**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
25.00 t/h



### **CN, Shijiazhuang**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
31.25 t/h



### **CN, Muping**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
16.70 t/h



### **CN, Tonghua**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
16.70 t/h



### **CN, Meishan**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
20.83 t/h



### **IE, Dublin**

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
Scrubber Reactant  
Reactant  
Throughput per line  
Concept  
Electric power output  
Output

Air-cooled Grate  
Municipal Solid Waste  
2  
41.00 t/h  
102.5 MW  
4-pass boiler  
125 t/h at 62 bar(a) and 443 °C  
SNCR, Fabric Filter, Scrubber,  
Semi-dry Reactor  
Caustic Soda  
Lignite Coke, Calcium Hydroxide  
189'000 m³/h (STP)  
Condensation Turbine  
68.80 MW (gross)  
Electrical Power, Hot Water



### CN, Lhasa

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
14.60 t/h



### JP, Tokyo (Suginami)

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h  
49.70 MW  
Hot Water, Electrical Power



### GB, Herefordshire and Worcestershire

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line

Air-cooled Grate  
Municipal Solid Waste  
1  
30.55 t/h  
67.89 MW  
5-pass boiler  
86 t/h at 60 bar(a) and 415 °C  
SNCR, Fabric Filter, Semi-dry  
Reactor  
Calcium Hydroxide, Activated  
Carbon  
126'000 m³/h (STP)  
Condensation Turbine  
20.00 MW (gross)  
Electrical Power

Boiler

Concept  
Superheated Steam

Flue gas treatment

Concept

Reactant

Energy recovery

Throughput per line  
Concept  
Electric power output  
Output



### CN, Xiamen (Ruikepang reCulture)

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
10.42 t/h  
24.05 MW  
54'257 m³/h (STP)

Flue gas treatment



### **CN, Guangan**

Start of operation	2017	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	23.26 MW
Flue gas treatment	Concept	
	Throughput per line	55'266 m³/h (STP)




### **CN, Haikou II**

Start of operation	2017	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	25.00 t/h
	Thermal power per line	49.31 MW
Flue gas treatment	Concept	
	Throughput per line	115'540 m³/h (STP)




### **VN, Hanoi**

Start of operation	2017	
Combustion	Concept	Rotary Kiln
	Fuel	Industrial Waste
	Number of Lines	1
	Throughput per line	3.13 t/h
Energy recovery	Output	Electrical Power



### **CN, Bozhou**

Start of operation	2017	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h




### **CN, Kaixian**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h



### **CN, Linqi**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h



### **CN, Huaxi**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
25.00 t/h




### **CN, Wuhu**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
25.00 t/h




### **CN, Yíshui**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Jùlù**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
3  
20.83 t/h




### **CN, Wèi Xiàn**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
16.67 t/h




### **CN, Línqíng**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Xinjǐ**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Qian'an**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Shuangchéng**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
20.83 t/h




### **CN, Ch?xiòng**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h




### **CN, Lánlíng**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
2  
16.67 t/h




### **CN, Chéngwú**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Beijing, Pínggu**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Dehui Phase II**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
16.67 t/h




### **CN, Zhàodong**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
20.83 t/h




### **CN, Línqíng Phase II**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Qian'an Phase II**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
12.50 t/h




### **CN, Shuangchéng Phase II**

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line


In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
20.83 t/h



### CN, Wèi Xiàn Phase II

Start of operation	2017
Combustion	Concept
	Fuel
	Number of Lines
	Throughput per line


In construction
Air-cooled Grate
Municipal Solid Waste
1
16.67 t/h



### CN, Xínjǐ Phase II

Start of operation	2017
Combustion	Concept
	Fuel
	Number of Lines
	Throughput per line


In construction
Air-cooled Grate
Municipal Solid Waste
1
12.50 t/h



### CN, Yíshuǐ Phase II

Start of operation	2017
Combustion	Concept
	Fuel
	Number of Lines
	Throughput per line


In construction
Air-cooled Grate
Municipal Solid Waste
1
12.50 t/h



### CN, Chéngd?

Start of operation	2017
Combustion	Concept
	Fuel
	Number of Lines
	Throughput per line

In construction
Air-cooled Grate
Municipal Solid Waste
3
20.83 t/h




### JP, Kurokawa II

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
1.04 t/h




### JP, Kiso

Start of operation  
Combustion

2017  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
0.25 t/h



### FR, Barberey

Start of operation  
Anaerobic Digestion

Gas Upgrading

2017  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### CH, Niedergösgen

Start of operation  
Gas Upgrading

2017  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Sewage Sludge  
400 Nm<sup>3</sup>/h  
280 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Noyen

Start of operation  
Anaerobic Digestion

Gas Upgrading

2017	
Number of Digester(s)	2
Net volume per digester	2'300 m <sup>3</sup>
Digester Type	Wet AD
Technology	Membrane Technology
Input Gas	Biogas from Agricultural Residues
Plant Capacity	500 Nm <sup>3</sup> /h
Hourly Biomethane Production	250 Nm <sup>3</sup> /h
Biomethane Usage	Biomethane for gas-grid injection



### FR, Saints

Start of operation  
Anaerobic Digestion

Gas Upgrading

2017	
Number of Digester(s)	2
Net volume per digester	2'300 m <sup>3</sup>
Digester Type	Wet AD
Technology	Membrane Technology
Input Gas	Biogas from Agricultural Residues
Plant Capacity	500 Nm <sup>3</sup> /h
Hourly Biomethane Production	250 Nm <sup>3</sup> /h
Biomethane Usage	Biomethane for gas-grid injection



### CH, Thun

Start of operation  
Gas Upgrading

2017	
Technology	Membrane Technology
Input Gas	Biogas from Sewage Sludge
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	130 Nm <sup>3</sup> /h
Biomethane Usage	Biomethane for gas-grid injection



### CN, Zhuhai

Start of operation  
Combustion

2016	
Concept	Air-cooled Grate
Fuel	Municipal Solid Waste
Number of Lines	2
Throughput per line	25.00 t/h



### JP, Fujimino, Saitama

Start of operation	2016	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	3.00 t/h
	Thermal power per line	10.30 MW
Energy recovery	Output	Hot Water, Electrical Power



### PL, Poznan

Start of operation	2016	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	15.00 t/h
	Thermal power per line	31.50 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	38 t/h at 62 bar(a) and 422 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter
	Reactant	Calcium Hydroxide
Energy recovery	Throughput per line	66'000 m³/h (STP)
	Concept	Condensation Turbine
	Electric power output	17.30 MW (gross)
	Output	Electrical Power, Hot Water




### GB, Severnside L1, L2

Start of operation	2016	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	24.24 t/h
	Thermal power per line	62.61 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	78 t/h at 62 bar(a) and 422 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter
	Reactant	Calcium Hydroxide
Energy recovery	Throughput per line	127'000 m³/h (STP)
	Concept	Condensation Turbine
	Electric power output	37.40 MW (gross)
	Output	Electrical Power



### IN, Essel Jabalpur

Start of operation	2016	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	25.00 t/h
	Thermal power per line	47.97 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	57 t/h at 46 bar(a) and 410 °C
Flue gas treatment	Concept	Evaporation cooler, Fabric Filter
	Reactant	Calcium Hydroxide, Activated Carbon
	Throughput per line	112'178 m³/h (STP)



### TH, Bangkok (Nong Khaem)

Start of operation	2016	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	10.40 t/h




### JP, Tsuyama, Okayama

Start of operation	2016	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.67 t/h
	Thermal power per line	9.40 MW



### CN, Wuxi Xidong

Start of operation	2016	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	4
	Throughput per line	20.83 t/h
	Thermal power per line	38.77 MW
Flue gas treatment	Concept	SNCR, Spray Absorber, Fabric Filter
	Reactant	Activated Carbon, Calcium Hydroxide
	Throughput per line	100'950 m³/h (STP)
Energy recovery	Output	Electrical Power




### **CN, Dehui**

Start of operation  
Combustion

2016  
Concept  
Fuel  
Number of Lines  
Throughput per line

In construction  
Air-cooled Grate  
Municipal Solid Waste  
1  
16.67 t/h




### **JP, Nikaho**

Start of operation  
Combustion

2016  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
0.60 t/h



### **JP, Yasu III**

Start of operation  
Combustion

2016  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
0.90 t/h



### **FR, Brie**

Start of operation  
Anaerobic Digestion

Gas Upgrading

2016  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### FR, Meaux

Start of operation  
Anaerobic Digestion

Gas Upgrading


2016	2
Number of Digester(s)	2'300 m <sup>3</sup>
Net volume per digester	Wet AD
Digester Type	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	500 Nm <sup>3</sup> /h
Plant Capacity	250 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	



### CN, Yongji

Start of operation  
Combustion

2015	In construction
Concept	Air-cooled Grate
Fuel	Municipal Solid Waste
Number of Lines	1
Throughput per line	10.40 t/h



### PL, Jarocin

Start of operation  
Anaerobic Digestion

2015	1
Number of Digester(s)	1'300 m <sup>3</sup>
Net volume per digester	RM18
Digester Type	Organic Fraction of Municipal
Waste Type	Solid Waste
Waste Throughput per Year	15'000 t/a



### GB, Buckinghamshire


Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2015	Air-cooled Grate
Concept	Municipal Solid Waste, Industrial
Fuel	Waste
Number of Lines	1
Throughput per line	39.40 t/h
Thermal power per line	101.7 MW
Concept	5-pass boiler
Superheated Steam	127 t/h at 52 bar(a) and 402 °C
Concept	SNCR, Fabric Filter, Semi-dry
Reactant	Reactor
Throughput per line	Activated Carbon, Calcium
Concept	Hydroxide
Electric power output	180'714 m <sup>3</sup> /h (STP)
Output	Condensation Turbine
	26.50 MW (gross)
	Electrical Power



### JP, Namie

Start of operation  
Combustion

Flue gas treatment

2015  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Reactant  
Throughput per line

Air-cooled Grate  
Radioactive waste  
1  
12.50 t/h  
45.00 MW  
Dry Sorption Reactor, Fabric Filter  
Calcium Hydroxide, Activated  
Carbon  
154'040 m<sup>3</sup>/h (STP)



### CH, Horgen

Start of operation  
Combustion

Boiler

Flue gas treatment

2015  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Steam  
Concept  
Reactant  
Throughput per line

Water-cooled Grate  
Municipal Solid Waste  
1  
5.14 t/h  
15.00 MW  
3-pass boiler with external  
economizer  
18 t/h at 30 bar(a)  
Dry Sorption Reactor, Electrostatic  
Precipitator (1 Field), Fabric Filter,  
Heat exchanger again, SCR  
Adsorbent, Sodium Bicarbonate  
25'300 m<sup>3</sup>/h (STP)



### GB, Ferrybridge

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2015  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
Reactant  
Throughput per line  
Concept  
Electric power output  
Output

Water-cooled Grate  
Municipal Solid Waste, Biomass,  
Refuse Derived Fuel, Wood  
2  
42.25 t/h  
117.4 MW  
5-pass boiler  
104 t/h at 72 bar(a) and 427 °C  
SNCR, Fabric Filter, Heat  
Exchanger, Semi-dry Reactor  
Activated Carbon, Calcium  
Hydroxide  
208'000 m<sup>3</sup>/h (STP)  
Condensation Turbine  
75.00 MW (gross)  
Steam, Electrical Power



### JP, Gotemba Oyama, Shizuoka

Start of operation	2015	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.97 t/h
	Thermal power per line	9.80 MW
Energy recovery	Output	Electrical Power




### JP, Hagi Nagato, Yamaguchi

Start of operation	2015	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.16 t/h
	Thermal power per line	4.75 MW
Energy recovery	Output	Hot Water



### CN, Yingtán

Start of operation	2015	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	16.67 t/h
	Thermal power per line	25.20 MW
Flue gas treatment	Concept	
	Throughput per line	63'115 m³/h (STP)



### CN, Shanghai Chongming

Start of operation	2015	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	10.42 t/h
	Thermal power per line	18.78 MW
Flue gas treatment	Concept	
	Throughput per line	44'189 m³/h (STP)



### JP, Murakami, Niigata

Start of operation	2015	
Combustion	Fuel	Municipal Solid Waste, Sewage Sludge
	Number of Lines	2
	Throughput per line	1.96 t/h
	Thermal power per line	6.10 MW
Energy recovery	Output	Hot Water, Electrical Power



### CN, Xiamen West

Start of operation	2015	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	20.10 MW
Flue gas treatment	Concept	SNCR, Spray Absorber, Fabric Filter
	Reactant	Calcium Hydroxide, Activated Carbon
Energy recovery	Throughput per line	54'170 m³/h (STP)
	Output	Electrical Power




### CN, Nanchong

Start of operation	2015	In construction
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	16.66 t/h
	Thermal power per line	31.98 MW
Flue gas treatment	Concept	SNCR, Spray Absorber, Fabric Filter
	Reactant	Activated Carbon, Calcium Hydroxide
Energy recovery	Throughput per line	83'230 m³/h (STP)
	Output	Electrical Power



### CH, Lucerne Perlen

Start of operation	2015	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	15.60 t/h
	Thermal power per line	47.00 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	57 t/h at 41 bar(a) and 410 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Dry Sorption Reactor 2, Electrostatic Precipitator (1 Field), Ext. Eco, Fabric Filter, Fabric Filter 2, Heat Exchanger, Heat exchanger 2, SCR
	Reactant	Sodium Bicarbonate, Lignite Coke, Calcium Hydroxide
	Throughput per line	78'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	28.10 MW (gross)
	Output	Steam, Electrical Power, Hot Water



### JP, Daigo II

Start of operation	2015	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	0.67 t/h



### DE, Heinfelde

Start of operation	2015	
Gas Upgrading	Technology	Amine Scrubbing
	Input Gas	Biogas from Source Separated Municipal Waste
	Plant Capacity	1'000 Nm³/h
	Hourly Biomethane Production	500 Nm³/h
	Biomethane Usage	Biomethane for gas-grid injection



### FR, Thennelières

Start of operation	2015	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	2'300 m <sup>3</sup>
Gas Upgrading	Digester Type	Wet AD
	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	500 Nm <sup>3</sup> /h
	Hourly Biomethane Production	250 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection




### DE, Wittenburg

Start of operation	2015	
Gas Upgrading	Technology	Membrane Technology
	Input Gas	Biogas from Agricultural Residues
	Plant Capacity	700 Nm <sup>3</sup> /h
	Hourly Biomethane Production	350 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### CN, Shanghai Liming

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
Flue gas treatment	Number of Lines	4
	Throughput per line	20.83 t/h
	Thermal power per line	37.62 MW
	Concept	SNCR, Dry Sorption Reactor, Fabric Filter, Scrubber
	Reactant	Calcium Hydroxide, Activated Carbon
	Throughput per line	103'810 m <sup>3</sup> /h (STP)
Energy recovery	Output	Electrical Power



### CN, Xiangtan

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	4
	Throughput per line	20.83 t/h



### **CN, Shanghai Laogang**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	4
	Throughput per line	31.25 t/h
	Thermal power per line	61.80 MW
Energy recovery	Output	Electrical Power



### **CN, Sanya**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	14.58 t/h



### **CN, Harbin**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	25.00 t/h



### **JP, Bekki Hayami, Oita**

Start of operation	2014	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	4.90 t/h
	Thermal power per line	14.60 MW
Energy recovery	Output	Electrical Power



### **CN, Tianjin Binghai**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	20.83 t/h
	Thermal power per line	38.80 MW
Flue gas treatment	Concept	SNCR, Spray Absorber, Fabric Filter
	Reactant	Calcium Hydroxide, Activated Carbon
	Throughput per line	100'250 m³/h (STP)
Energy recovery	Output	Electrical Power



### **CN, Zhuzhou**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	20.83 t/h



### **CN, Rongcheng**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	14.58 t/h



### **CN, Shuyang**

Start of operation	2014	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	14.58 t/h



### **CN, Xingyi**

Start of operation  
Combustion

2014  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h



### **FI, Vantaa**

Start of operation  
Combustion

2014  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept

Water-cooled Grate  
Municipal Solid Waste  
2  
24.00 t/h  
64.20 MW  
4-pass boiler with external economizer  
83 t/h at 91 bar(a) and 400 °C  
SNCR  
111'100 m³/h (STP)

Boiler

Flue gas treatment

Superheated Steam  
Concept  
Throughput per line



### **CN, Dalian**

Start of operation  
Combustion

2014  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept

Air-cooled Grate  
Municipal Solid Waste  
3  
20.83 t/h  
38.80 MW  
SNCR, Spray Absorber, Fabric Filter  
Activated Carbon, Calcium Hydroxide  
100'250 m³/h (STP)  
Electrical Power

Flue gas treatment

Energy recovery

Reactant  
Throughput per line  
Output



### **CH, Winterthur Digester**

Start of operation  
Anaerobic Digestion

2014  
Number of Digester(s)  
Net volume per digester  
Waste Type

1  
1'500 m³  
Bio Waste, Food Waste, Green Waste

Gas Upgrading

Waste Throughput per Year  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

25'000 t/a  
Amine Scrubbing  
Biogas from Green Waste & Bio Waste  
300 Nm³/h  
122 Nm³/h  
Biomethane for gas-grid injection




### CH, Vétroz

Start of operation  
Anaerobic Digestion

Gas Upgrading

2014	1
Number of Digester(s)	1'300 m <sup>3</sup>
Net volume per digester	PF1300
Digester Type	Bio Waste, Green Waste, Liquid Manure, Waste Oil
Waste Type	20'000 t/a
Waste Throughput per Year	Amine Scrubbing
Technology	Biogas from Green Waste & Bio Waste
Input Gas	250 Nm <sup>3</sup> /h
Plant Capacity	130 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	



### PT, Amarsul

Start of operation  
Anaerobic Digestion

2014	3
Number of Digester(s)	1'300 m <sup>3</sup>
Net volume per digester	PF1300
Digester Type	Organic Fraction of Municipal Solid Waste
Waste Type	60'000 t/a
Waste Throughput per Year	



### PL, Olawa

Start of operation  
Anaerobic Digestion


2014	2
Number of Digester(s)	1'300 m <sup>3</sup>
Net volume per digester	RM18
Digester Type	Organic Fraction of Municipal Solid Waste
Waste Type	25'000 t/a
Waste Throughput per Year	



### GB, Saint Nicholas Court Farm

Start of operation  
Gas Upgrading

2014	Membrane Technology
Technology	Biogas from Agricultural Residues
Input Gas	700 Nm <sup>3</sup> /h
Plant Capacity	350 Nm <sup>3</sup> /h
Hourly Biomethane Production	Biomethane for gas-grid injection
Biomethane Usage	




### JP, Oshima

Start of operation  
Combustion

2014  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
0.31 t/h



### JP, Mimasaka

Start of operation  
Combustion

2014  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
0.71 t/h



### DE, Feldberg

Start of operation  
Gas Upgrading

2014  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Méry-sur-Seine

Start of operation  
Anaerobic Digestion

Gas Upgrading

2014  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Niederröblingen

Start of operation  
Gas Upgrading

2014  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Agricultural Residues  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Rackwitz

Start of operation  
Gas Upgrading

2014  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Agricultural Residues  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Sourdun

Start of operation  
Anaerobic Digestion

Gas Upgrading

2014  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Ussy-sur-Marne

Start of operation  
Anaerobic Digestion

Gas Upgrading

2014  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

2  
2'300 m<sup>3</sup>  
Wet AD  
Membrane Technology  
Biogas from Agricultural Residues  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### CH, Zuchwil

Start of operation  
Gas Upgrading

2014  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Sewage Sludge  
250 Nm<sup>3</sup>/h  
130 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### KR, Namyangju

Start of operation  
Combustion

2013  
Concept  
Fuel  
Number of Lines  
Throughput per line

Fluidised Bed Gasification  
Municipal Solid Waste  
1  
2.66 t/h



### CN, Changshu

Start of operation  
Combustion

2013  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
3  
12.50 t/h



### CN, Yantai

Start of operation  
Combustion

2013  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
20.83 t/h



### JP, Nantan

Start of operation  
Anaerobic Digestion

2013  
Number of Digester(s)  
Net volume per digester  
Waste Type  
Waste Throughput per Year

1  
1'030 m<sup>3</sup>  
Organic Fraction of Municipal  
Solid Waste  
10'800 t/a



### JP, Matsuyama, Ehime

Start of operation  
Combustion

Energy recovery

2013  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

Municipal Solid Waste  
3  
5.83 t/h  
16.90 MW  
Electrical Power



### JP, Nishiharima, Hyogo

Start of operation  
Combustion

Energy recovery

2013  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

Municipal Solid Waste  
2  
1.85 t/h  
5.80 MW  
Electrical Power, Hot Water



### JP, Nakakita Sorachi, Hokkaido

Start of operation  
Combustion

Boiler

Energy recovery

2013  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Steam  
Output

Municipal Solid Waste  
2  
1.77 t/h  
8.20 MW  
3-pass boiler  
Electrical Power



### DE, Coesfeld

Start of operation  
Anaerobic Digestion

2013  
Number of Digester(s) 2  
Net volume per digester 1'300 m<sup>3</sup>  
Digester Type PF1300  
Waste Type Bio Waste, Green Waste  
Waste Throughput per Year 40'000 t/a



### CN, Haikou

Start of operation  
Combustion

Energy recovery

2013  
Concept  
Fuel  
Number of Lines 2  
Throughput per line 25.00 t/h  
Thermal power per line 46.00 MW  
Output  
Electrical Power  
Air-cooled Grate  
Municipal Solid Waste



### JP, Hadano Isehara, Kanagawa

Start of operation  
Combustion

Energy recovery

2013  
Fuel  
Number of Lines 2  
Throughput per line 4.16 t/h  
Thermal power per line 13.30 MW  
Output  
Electrical Power  
Municipal Solid Waste



### GB, Cleveland L4, L5

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2013  
Concept  
Fuel  
Number of Lines 2  
Throughput per line 19.00 t/h  
Thermal power per line 45.85 MW  
Concept  
Superheated Steam 56 t/h at 50 bar(a) and 410 °C  
Concept  
Reactant  
Throughput per line 95'400 m<sup>3</sup>/h (STP)  
Concept  
Condensation Turbine  
Electric power output 26.00 MW (gross)  
Output  
Electrical Power  
Air-cooled Grate  
Municipal Solid Waste, Industrial Waste  
4-pass boiler  
SNCR, Fabric Filter, Semi-dry Reactor  
Activated Carbon, Calcium Hydroxide



### **CN, Longyan**

Start of operation  
Combustion

Flue gas treatment

2013  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Concept

Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h  
Dry Sorption Reactor, Semi-dry  
Reactor, Fabric Filter



### **CN, Rudong II**

Start of operation  
Combustion

Flue gas treatment

2013  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Concept

Air-cooled Grate  
Municipal Solid Waste  
1  
20.83 t/h  
Dry Sorption Reactor, Fabric Filter



### **DE, Fulda**

Start of operation  
Anaerobic Digestion

2013  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Waste Type  
Waste Throughput per Year

2  
1'300 m<sup>3</sup>  
PF1300  
Bio Waste, Green Waste  
32'000 t/a



### **NL, Tilburg**

Start of operation  
Anaerobic Digestion

2013  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Waste Type  
Waste Throughput per Year

2  
1'300 m<sup>3</sup>  
PF1300  
Bio Waste, Green Waste  
46'000 t/a



### CH, Zurich Werdhölzli

Start of operation	2013	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'500 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	25'000 t/a




### FR, Clermont-Ferrand

Start of operation	2013	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	15'000 t/a



### JP, Hofu

Start of operation	2013	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	750 m <sup>3</sup>
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	17'500 t/a



### JP, Hida

Start of operation	2013	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	0.52 t/h



### **DE, Altenhof**

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Gardelegen**

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Jabel**

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Kirchzellersen**

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Kroppenstedt

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Werlte

Start of operation  
Gas Upgrading

2013  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'000 Nm<sup>3</sup>/h  
500 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### CN, Huzhou

Start of operation  
Combustion

Flue gas treatment

Energy recovery

2012  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Concept  
Output

Air-cooled Grate  
Municipal Solid Waste  
1  
8.33 t/h  
Fabric Filter, Semi-dry Reactor, SNCR  
Electrical Power



### FI, Vaasa

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2012  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
Throughput per line  
Output

Water-cooled Grate  
Municipal Solid Waste, Industrial Waste  
1  
24.00 t/h  
61.00 MW  
4-pass boiler  
74 t/h at 42 bar(a) and 402 °C  
SNCR  
104'140 m<sup>3</sup>/h (STP)  
Hot Water, Electrical Power



### CH, Hinwil

Start of operation  
Flue gas treatment

2012  
Concept

Number of Lines  
Fuel  
Reactant

Throughput per line

Dry Sorption Reactor, Fabric Filter, Heat Exchanger, SCR  
2  
Municipal Solid Waste  
Sodium Bicarbonate, Activated Carbon  
87'500 m³/h (STP)



### ES, Sant Adrià de Besòs L1-L3

Start of operation  
Combustion

2012  
Concept  
Fuel

Boiler

Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam

Air-cooled Grate  
Industrial Waste, Municipal Solid Waste  
3  
15.00 t/h  
48.80 MW  
3-pass boiler  
50 t/h at 40 bar(a) and 400 °C



### CN, Ningde

Start of operation  
Combustion

2012  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Concept

Flue gas treatment

Air-cooled Grate  
Municipal Solid Waste  
2  
12.50 t/h  
Dry Sorption Reactor, Semi-dry Reactor, Fabric Filter



### TH, Phuket

Start of operation  
Combustion

2012  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Concept

Flue gas treatment

Air-cooled Grate  
Municipal Solid Waste  
2  
14.58 t/h  
Semi-dry Reactor, Fabric Filter



### FR, Vannes

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Organic Fraction of Municipal Solid Waste
Waste Throughput per Year	15'000 t/a



### FR, Angers

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	4
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Organic Fraction of Municipal Solid Waste
Waste Throughput per Year	50'000 t/a



### DE, Witten

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	26'300 t/a



### DE, Trittau

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste
Waste Throughput per Year	20'000 t/a



### IT, Faedo

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	2
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	32'000 t/a



### IT, Terni

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	17'500 t/a



### NL, Weurt

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	2
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	38'000 t/a



### IT, Novi Ligure

Start of operation  
Anaerobic Digestion

2012	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	16'800 t/a



### **DE, Heidenau**

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Karben**

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Klein Wanzleben**

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Leizen**

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### DE, Marienthal

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Müden-Aller

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### DE, Neudorf-Helle

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Rätzlingen

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Rosche

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Zeven II

Start of operation  
Gas Upgrading

2012  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Membrane Technology  
Biogas from Energy Crops  
250 Nm<sup>3</sup>/h  
130 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Forbach

Start of operation  
Anaerobic Digestion

2011  
Number of Digester(s)  
Net volume per digester  
Digester Type  
Waste Type  
Waste Throughput per Year

3  
1'300 m<sup>3</sup>  
PF1300  
Bio Waste, Green Waste  
42'000 t/a



### GB, Newhaven

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2011  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
Throughput per line  
Concept  
Electric power output  
Output

Air-cooled Grate  
Municipal Solid Waste  
2  
14.50 t/h  
35.85 MW  
4-pass boiler  
44 t/h at 50 bar(a) and 400 °C  
SNCR, Semi-dry Reactor, Fabric  
Filter  
75'600 m<sup>3</sup>/h (STP)  
Condensation Turbine  
19.25 MW (gross)  
Electrical Power



### NO, Oslo

Start of operation  
Combustion

2011  
Concept  
Fuel

Boiler

Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept

Flue gas treatment

Scrubber Reactant  
Throughput per line  
Concept  
Electric power output  
Output

Energy recovery

Water-cooled Grate  
Municipal Solid Waste, Industrial  
Waste  
1  
24.00 t/h  
66.70 MW  
4-pass boiler  
78 t/h at 42 bar(a) and 402 °C  
Electrostatic Precipitator (3  
Fields), Heat Exchanger,  
Scrubber, Heat exchanger again,  
Heat exchanger 2, Heat  
exchanger 3, SCR, Heat  
exchanger 2 again  
Lye  
130'000 m³/h (STP)  
Back-pressure Turbine  
12.80 MW (gross)  
Hot Water, Electrical Power



### JP, Iwata Bannan II, Shizuoka

Start of operation  
Combustion

2011  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Output

Energy recovery

Municipal Solid Waste  
2  
4.67 t/h  
3.00 MW  
Hot Water, Electrical Power



### GB, Riverside, London

Start of operation  
Combustion

2011  
Concept  
Fuel

Boiler

Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept

Flue gas treatment

Throughput per line  
Concept  
Electric power output  
Output

Energy recovery

Air-cooled Grate  
Municipal Solid Waste, Industrial  
Waste  
3  
32.44 t/h  
81.10 MW  
4-pass boiler  
99 t/h at 72 bar(a) and 427 °C  
SNCR, Semi-dry Reactor, Fabric  
Filter  
169'800 m³/h (STP)  
Condensation Turbine  
73.00 MW (gross)  
Electrical Power



### NL, Roosendaal

Start of operation	2011	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	21.00 t/h
	Thermal power per line	62.00 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	76 t/h at 62 bar(a) and 422 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SCR, Electrostatic Precipitator
	Reactant	Sodium Bicarbonate
	Throughput per line	127'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	28.70 MW (gross)
	Output	Hot Water, Electrical Power



### CN, Xiangyang

Start of operation	2011	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	16.67 t/h
Flue gas treatment	Concept	Semi-dry Reactor, Fabric Filter



### DE, Neunkirchen EEW

Start of operation	2011	
Flue gas treatment	Concept	Spray Dryer, Fabric Filter, Scrubber
	Number of Lines	2
	Fuel	Municipal Solid Waste
	Throughput per line	50'000 m³/h (STP)



### CN, Rudong

Start of operation	2011	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	10.42 t/h
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter



### IT, Belluno

Start of operation  
Anaerobic Digestion

2011	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Food Waste, Green Waste
Waste Throughput per Year	22'000 t/a



### DE, Ennigerloh

Start of operation  
Anaerobic Digestion

2011	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	21'000 t/a



### DE, Backnang-Neuschöntal

Start of operation  
Anaerobic Digestion

2011	
Number of Digester(s)	2
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	36'000 t/a



### CH, Wauwil

Start of operation  
Anaerobic Digestion

2011	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	PF1300
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	16'000 t/a



### CH, Chavornay

Start of operation	2011	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'500 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	23'000 t/a



### DE, Ingolstadt

Start of operation	2011	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	20'000 t/a



### DE, Altena

Start of operation	2011	
Gas Upgrading	Technology	Amine Scrubbing
	Input Gas	Biogas from Energy Crops
	Plant Capacity	700 Nm <sup>3</sup> /h
	Hourly Biomethane Production	350 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### DE, Apensen

Start of operation	2011	
Gas Upgrading	Technology	Amine Scrubbing
	Input Gas	Biogas from Energy Crops
	Plant Capacity	700 Nm <sup>3</sup> /h
	Hourly Biomethane Production	350 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection



### DE, Bruchhausen-Vilsen

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Gross Kelle

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Jürgenshagen

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Karft

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Source Separated  
Municipal Waste  
1'000 Nm<sup>3</sup>/h  
500 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Malstedt

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Oberriexingen

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### DE, Schwedt

Start of operation  
Gas Upgrading

2011  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'400 Nm<sup>3</sup>/h  
700 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### JP, Osaka IV

Start of operation  
Combustion

2010  
Concept  
Fuel

Number of Lines  
Throughput per line

Rotary Kiln  
Industrial Waste, Sewage Sludge,  
Waste Oil, Green Waste, Wood  
Waste  
1  
4.46 t/h



### JP, Yamagata, Gifu

Start of operation	2010	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	0.75 t/h
Boiler	Concept	Water Injection
	Steam	



### LU, Leudelange TABA

Start of operation	2010	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	22.00 t/h
	Thermal power per line	67.00 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	79 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SCR
	Reactant	Lignite Coke, Sodium Bicarbonate
	Throughput per line	136'642 m³/h (STP)
Energy recovery	Output	Electrical Power



### US, Olmsted L5, MN

Start of operation	2010	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste, Waste Oil
	Number of Lines	1
	Throughput per line	7.93 t/h
	Thermal power per line	23.30 MW
Boiler	Concept	2-pass boiler
	Superheated Steam	29 t/h at 44 bar(a) and 346 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Spray Dryer
	Throughput per line	46'300 m³/h (STP)
Energy recovery	Output	Electrical Power, Steam



### NO, Bergen L2

Start of operation	2010	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	16.00 t/h
	Thermal power per line	44.80 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	57 t/h at 43 bar(a) and 402 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Scrubber, Semi-dry Reactor
	Scrubber Reactant	Caustic Soda
	Reactant	Lignite Coke, Calcium Hydroxide
	Throughput per line	92'000 m³/h (STP)
Energy recovery	Output	Hot Water, Electrical Power



### DE, Aurich-Grossefehn

Start of operation	2010	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	18'000 t/a



### NL, Rijsenhout

Start of operation	2010	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	42'000 t/a



### CH, Villeneuve

Start of operation	2010	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	20'000 t/a



### NL, Zwolle

Start of operation	2010	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	45'000 t/a



### **DE, Drögenndorf**

Start of operation  
Gas Upgrading

2010  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
500 Nm<sup>3</sup>/h  
250 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Eggertshofen**

Start of operation  
Gas Upgrading

2010  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
400 Nm<sup>3</sup>/h  
200 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Grabsleben**

Start of operation  
Gas Upgrading

2010  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### **DE, Unsleben**

Start of operation  
Gas Upgrading

2010  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
700 Nm<sup>3</sup>/h  
350 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### BE, Intradel

Start of operation  
Combustion

2009  
Concept  
Fuel

Water-cooled Grate  
Municipal Solid Waste, Sewage  
Sludge

Boiler

Number of Lines  
Throughput per line  
Thermal power per line  
Concept

2  
23.63 t/h  
67.10 MW  
3-pass boiler with external  
economizer

Flue gas treatment

Superheated Steam  
Concept

80 t/h at 40 bar(a) and 400 °C  
Electrostatic Precipitator (1 Field),  
Ext. Eco, SCR, Spray Absorber,  
Dry Sorption Reactor

Throughput per line

141'000 m³/h (STP)



### CN, Chengdu Luodai

Start of operation  
Combustion

2009  
Concept  
Fuel

Air-cooled Grate  
Municipal Solid Waste  
3

Flue gas treatment

Number of Lines  
Throughput per line  
Concept

16.70 t/h  
SNCR, Dry Sorption Reactor,  
Fabric Filter  
Activated Carbon, Calcium  
Hydroxide

Reactant

Energy recovery

Throughput per line  
Output

93'720 m³/h (STP)  
Electrical Power



### KR, Iksan

Start of operation  
Combustion

2009  
Fuel

Municipal Solid Waste  
2

Energy recovery

Number of Lines  
Throughput per line  
Thermal power per line  
Output

4.17 t/h  
3.90 MW  
Electrical Power



### JP, Osaka (Higashiyodo)

Start of operation  
Combustion

2009  
Concept  
Fuel

Air-cooled Grate  
Municipal Solid Waste  
2

Energy recovery

Number of Lines  
Throughput per line  
Thermal power per line  
Output

8.33 t/h  
12.00 MW  
Steam, Electrical Power



### **JP, Aira**

Start of operation  
Combustion

Boiler

2009  
Fuel  
Number of Lines  
Throughput per line  
Concept  
Steam

Municipal Solid Waste  
2  
1.54 t/h  
Water Injection



### **AT, Zistersdorf**

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2009  
Concept  
Fuel  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
  
Reactant  
Throughput per line  
Concept  
Electric power output  
Output

Water-cooled Grate  
Municipal Solid Waste  
1  
19.79 t/h  
57.80 MW  
4-pass boiler  
68 t/h at 42 bar(a) and 405 °C  
Fabric Filter, SCR, Dry Sorption  
Reactor  
Sodium Bicarbonate  
97'000 m³/h (STP)  
Condensation Turbine  
14.90 MW (gross)  
Electrical Power



### **ES, Mallorca**

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery

2009  
Concept  
Fuel  
  
Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept  
  
Throughput per line  
Output

Water-cooled Grate  
Municipal Solid Waste, Sewage  
Sludge  
2  
27.00 t/h  
70.00 MW  
3-pass boiler  
82 t/h at 52 bar(a) and 400 °C  
Semi-dry Reactor, Fabric Filter,  
Heat Exchanger, Heat exchanger  
2, SCR, Heat exchanger again  
142'000 m³/h (STP)  
Electrical Power



### GB, Cleveland L3

Start of operation	2009	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	19.00 t/h
	Thermal power per line	45.80 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	55 t/h at 43 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Semi-dry Reactor
	Reactant	Calcium Hydroxide, Activated Carbon
	Throughput per line	94'600 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	10.00 MW (gross)
	Output	Electrical Power



### CH, Altdorf

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	340 m³
	Waste Type	Food Waste, Green Waste
	Waste Throughput per Year	5'000 t/a



### ES, Botarell

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	1'300 m³
	Digester Type	PF1300
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	54'000 t/a



### QA, Doha

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	15
	Net volume per digester	1'300 m³
	Digester Type	PF1300
	Waste Type	Green Waste, Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	274'000 t/a



### CH, Oensingen

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	18'000 t/a




### FR, Saint Lô

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Green Waste, Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	22'000 t/a



### CH, Volketswil

Start of operation	2009	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	20'000 t/a
Gas Upgrading	Technology	Amine Scrubbing
	Biomethane Usage	Biomethane for gas-grid injection, Combined Heat and Power



### JP, Aira

Start of operation	2009	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	1.54 t/h




### DE, Einbeck

Start of operation  
Gas Upgrading

2009  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'000 Nm<sup>3</sup>/h  
500 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection




### DE, Hardeggen

Start of operation  
Gas Upgrading

2009  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
1'100 Nm<sup>3</sup>/h  
550 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Horn-Bad Meinberg

Start of operation  
Gas Upgrading

2009  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
2'000 Nm<sup>3</sup>/h  
1'000 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### DE, Zeven

Start of operation  
Gas Upgrading

2009  
Technology  
Input Gas  
Plant Capacity  
Hourly Biomethane Production  
Biomethane Usage

Amine Scrubbing  
Biogas from Energy Crops  
250 Nm<sup>3</sup>/h  
130 Nm<sup>3</sup>/h  
Biomethane for gas-grid injection



### FR, Argenteuil L4

Start of operation	2008	Air-cooled Grate Municipal Solid Waste
	Concept	
Boiler	Fuel	16.50 t/h 44.14 MW 4-pass boiler 54 t/h at 47 bar(a) and 380 °C
	Number of Lines	
	Throughput per line	
	Thermal power per line	
	Concept	
Energy recovery	Superheated Steam	Electrical Power
	Output	



### DE, Witzenhausen

Start of operation	2008	Circulating Fluidised Bed Refuse Derived Fuel, Pulp Sludge
	Concept	
Flue gas treatment	Fuel	34.92 t/h 125.3 MW SNCR, Semi-dry Reactor, Fabric Filter
	Number of Lines	
	Throughput per line	
	Thermal power per line	
	Concept	
Energy recovery	Throughput per line	207'100 m³/h (STP) Steam, Electrical Power
	Output	



### JP, Osumi-kimotsuki, Kagoshima Pref.

Start of operation	2008	Fluidised Bed Gasification
	Concept	
Combustion	Fuel	2 2.66 t/h
	Number of Lines	
	Throughput per line	



### CN, Xiamen Garbage Treatment

Start of operation	2008	Air-cooled Grate Municipal Solid Waste
	Concept	
Boiler	Fuel	9.00 t/h 14.65 MW 3-pass boiler 18 t/h at 40 bar(a) and 400 °C
	Number of Lines	
	Throughput per line	
	Thermal power per line	
	Concept	
Flue gas treatment	Superheated Steam	Semi-dry Reactor, Fabric Filter 42'000 m³/h (STP)
	Concept	
Energy recovery	Throughput per line	Electrical Power
	Output	



### NL, Moerdijk L4

Start of operation	2008	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	38.33 t/h
	Thermal power per line	95.80 MW
Boiler	Concept	2-pass boiler
	Superheated Steam	121 t/h at 107 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Ext. Eco, Scrubber, Dry Sorption Reactor
	Scrubber Reactant	Lye
	Throughput per line	199'200 m³/h (STP)
Energy recovery	Concept	Back-pressure Turbine
	Electric power output	13.47 MW (gross)
	Output	Steam, Electrical Power



### CH, Giubiasco

Start of operation	2008	
Flue gas treatment	Concept	Electrostatic Precipitator (3 Fields), Ext. Eco, Fabric Filter, Fly Ash Treatment, Heat Exchanger, Heat exchanger 2, Heat exchanger 2 again, Heat exchanger 3, Heat exchanger again, SCR, Scrubber, Activated Carbon Entrainment
	Number of Lines	2
	Fuel	Municipal Solid Waste
	Scrubber Reactant	Caustic Soda
	Reactant	Lignite Coke
	Throughput per line	67'430 m³/h (STP)



### FR, Pithiviers

Start of operation	2008	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	4.00 t/h
	Thermal power per line	10.93 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	13 t/h at 40 bar(a) and 380 °C
Flue gas treatment	Concept	SNCR, Dry Sorption Reactor, Fabric Filter
	Reactant	Sodium Bicarbonate
	Throughput per line	24'000 m³/h (STP)
Energy recovery	Output	Steam, Electrical Power



### DE, Flörsheim Wicker

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	GG20
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	45'000 t/a



### CH, Klingnau

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	GG20
	Waste Type	Bio Waste, Food Waste, Green Waste, Liquid Waste
	Waste Throughput per Year	20'000 t/a



### CH, Lavigny

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	960 m <sup>3</sup>
	Digester Type	GG16
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	16'000 t/a



### FR, Montpellier

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	8
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	100'000 t/a



### CH, Inwil

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	960 m <sup>3</sup>
	Digester Type	GG16
	Waste Type	Bio Waste, Green Waste, Liquid Manure, Liquid Waste, Solid Manure
	Waste Throughput per Year	16'000 t/a



### NL, Wilp-Achterhoeck

Start of operation	2008	
Anaerobic Digestion	Number of Digester(s)	4
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	PF1300
	Waste Type	Bio Waste, Green Waste, Liquid Waste
	Waste Throughput per Year	60'000 t/a



### FR, Dunkerque

Start of operation	2007	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	12.00 t/h
	Thermal power per line	29.30 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	35 t/h at 40 bar(a) and 380 °C
Flue gas treatment	Concept	SCR, Scrubber, Electrostatic Precipitator
	Scrubber Reactant	Caustic Soda
	Reactant	Lignite Coke
	Throughput per line	50'000 m <sup>3</sup> /h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	6.00 MW (gross)
	Output	Electrical Power



### JP, Sano, Tochigi Pref.

Start of operation	2007	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	5.33 t/h



### NO, Trondheim L3

Start of operation	2007	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	17.29 t/h
	Thermal power per line	45.80 MW
Boiler	Concept	2-pass boiler
	Hot Water	911 t/h at 16 bar(a) and 180 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter, Scrubber
	Scrubber Reactant	Lye
	Throughput per line	84'000 m³/h (STP)
Energy recovery	Output	Hot Water



### JP, Toyota, Aichi Pref.

Start of operation	2007	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	5.63 t/h



### JP, Kitashiribeshi, Hokkaido

Start of operation	2007	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	4.10 t/h
	Thermal power per line	2.00 MW
Energy recovery	Output	Electrical Power



### DE, Bamberg L1 - L3

Start of operation	2007	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste, Industrial Waste, Sewage Sludge
	Number of Lines	3
	Throughput per line	6.00 t/h
	Thermal power per line	17.50 MW
Boiler	Concept	5-pass boiler
	Superheated Steam	20 t/h at 40 bar(a) and 400 °C
Energy recovery	Output	Hot Water



### DE, Stassfurt EVZA

Start of operation	2007	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste, Industrial Waste
	Number of Lines	2
	Throughput per line	22.50 t/h
	Thermal power per line	55.60 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	64 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter
	Throughput per line	116'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	28.14 MW (gross)
	Output	Steam, Electrical Power



### FR, Issy-les-Moulineaux

Start of operation	2007	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste
	Number of Lines	2
	Throughput per line	34.90 t/h
	Thermal power per line	85.23 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	104 t/h at 50 bar(a) and 400 °C
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SCR
	Reactant	Lignite Coke, Sodium Bicarbonate
	Throughput per line	151'000 m³/h (STP)
Energy recovery	Output	Electrical Power, Hot Water



### DE, Amtzell

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m³
	Digester Type	GG20
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	18'000 t/a



### DE, Gröbern

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m³
	Digester Type	GG20
	Waste Type	Energy Crops
	Waste Throughput per Year	17'000 t/a



### DE, Ilbenstadt

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	GG20
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	18'250 t/a



### CH, Oetwil am See 2

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	340 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	5'000 t/a



### DE, Regen

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	GG20
	Waste Type	Bio Waste, Energy Crops, Green Waste
	Waste Throughput per Year	18'000 t/a



### DE, Rostock

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	RM18
	Waste Type	Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	40'000 t/a



### CH, Utzenstorf

Start of operation	2007	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	720 m <sup>3</sup>
	Digester Type	GG12
	Waste Type	Bio Waste, Green Waste, Liquid Waste
	Waste Throughput per Year	12'000 t/a
Gas Upgrading	Hourly Biomethane Production	42 Nm <sup>3</sup> /h
	Biomethane Usage	Biomethane for gas-grid injection, Combined Heat and Power



### DE, Erfurt

Start of operation	2006	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste, Refuse Derived Fuel
	Number of Lines	1
	Throughput per line	9.75 t/h
	Thermal power per line	26.00 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	29 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Semi-dry Reactor
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	54'000 m <sup>3</sup> /h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	4.90 MW (gross)
	Output	Steam, Hot Water, Electrical Power



### FR, Sète

Start of operation	2006	
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter
	Number of Lines	1
	Fuel	Municipal Solid Waste
	Reactant	Sodium Bicarbonate
	Throughput per line	30'000 m <sup>3</sup> /h (STP)



### JP, Ariake, Kumamoto Pref.

Start of operation	2006	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	1.04 t/h
Boiler	Concept	Water Injection
	Steam	



### JP, Jonan Haseyama II

Start of operation	2006	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	5.00 t/h
	Thermal power per line	4.90 MW
Energy recovery	Output	Electrical Power



### JP, Tamura, Fukushima

Start of operation	2006	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	1.60 t/h
Energy recovery	Output	Steam



### JP, Tokyo (Shinagawa)

Start of operation	2006	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	15.00 MW
Energy recovery	Output	Hot Water, Electrical Power



### CH, Lausanne (Tridel)

Start of operation	2006	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste, Hospital Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	40.00 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	46 t/h at 52 bar(a) and 403 °C
Flue gas treatment	Concept	Electrostatic Precipitator (2 Fields), Ext. Eco, Fly Ash Treatment, Heat Exchanger, Heat exchanger 2, Heat exchanger 2 again, Heat exchanger 3, Heat exchanger again, SCR, Scrubber
	Scrubber Reactant	Caustic Soda
	Throughput per line	63'200 m³/h (STP)
Energy recovery	Output	Hot Water, Electrical Power



### CH, Aarberg

Start of operation  
Anaerobic Digestion

2006	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	GG20
Waste Type	Bio Waste, Food Waste, Green Waste
Waste Throughput per Year	20'000 t/a



### CH, Langenthal

Start of operation  
Anaerobic Digestion

2006	
Number of Digester(s)	1
Net volume per digester	240 m <sup>3</sup>
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	5'600 t/a



### CH, Ottenbach

Start of operation  
Anaerobic Digestion

2006	
Number of Digester(s)	1
Net volume per digester	960 m <sup>3</sup>
Digester Type	GG16
Waste Type	Bio Waste, Food Waste, Green Waste
Waste Throughput per Year	16'000 t/a



### CH, Pratteln

Start of operation  
Anaerobic Digestion

2006	
Number of Digester(s)	1
Net volume per digester	960 m <sup>3</sup>
Digester Type	GG16
Waste Type	Bio Waste, Food Waste, Green Waste
Waste Throughput per Year	15'000 t/a




### DE, Reimlingen

Start of operation	2006	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'300 m <sup>3</sup>
	Digester Type	GG20
	Waste Type	Energy Crops
	Waste Throughput per Year	27'000 t/a



### DE, Weissenfels 2

Start of operation	2006	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	960 m <sup>3</sup>
	Digester Type	GG16
	Waste Type	Bio Waste, Crop Residues
	Waste Throughput per Year	14'500 t/a



### JP, Kushimoto/Kozagawa

Start of operation	2006	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	0.63 t/h



### FR, Nantes Valorena

Start of operation	2005	
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter, SCR
	Number of Lines	2
	Fuel	Municipal Solid Waste
	Reactant	Sodium Bicarbonate
	Throughput per line	56'500 m <sup>3</sup> /h (STP)



### **JP, Kashiwa, Chiba**

Start of operation	2005	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	5.21 t/h
	Thermal power per line	2.50 MW
Energy recovery	Output	Hot Water, Electrical Power



### **KR, Incheon South**

Start of operation	2005	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	10.42 t/h
Energy recovery	Output	Steam



### **JP, Odate, Akita**

Start of operation	2005	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	1.88 t/h
Boiler	Concept	Water Injection
	Steam	
Energy recovery	Output	Hot Water



### **TW, Yunlin**

Start of operation	2005	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	15.80 MW
Energy recovery	Output	Electrical Power



### DE, Ludwigslust

Start of operation	2005	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	6.00 t/h
	Thermal power per line	16.00 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	19 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Fabric Filter, Semi-dry Reactor
	Reactant	Calcium Hydroxide, Lignite Coke
	Throughput per line	34'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	3.00 MW (gross)
	Output	Electrical Power



### DE, Zorbau

Start of operation	2005	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	21.00 t/h
	Thermal power per line	53.60 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	63 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter
	Throughput per line	118'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	28.30 MW (gross)
	Output	Electrical Power



### FR, Rennes L1+L2

Start of operation	2005	
Flue gas treatment	Concept	Fabric Filter, SCR, Dry Sorption Reactor
	Number of Lines	2
	Fuel	Municipal Solid Waste
	Reactant	Sodium Bicarbonate
	Throughput per line	40'400 m³/h (STP)
Energy recovery	Output	Steam, Electrical Power



### FR, Rennes L3

Start of operation	2005	
Flue gas treatment	Concept	Fabric Filter, SCR, Dry Sorption Reactor
	Number of Lines	1
	Fuel	Municipal Solid Waste
	Reactant	Sodium Bicarbonate
	Throughput per line	61'900 m³/h (STP)
Energy recovery	Output	Steam, Electrical Power




## SE, Uppsala (Block 5)

Start of operation	2005	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste, Hospital Waste
	Number of Lines	1
	Throughput per line	26.40 t/h
	Thermal power per line	73.33 MW
Boiler	Concept	4-pass boiler
	Saturated Steam	100 t/h at 20 bar(a) and 212 °C
Flue gas treatment	Concept	Electrostatic Precipitator (2 Fields), Scrubber, Fabric Filter, SCR
	Scrubber Reactant	Lye, Limestone
	Throughput per line	148'900 m³/h (STP)
Energy recovery	Output	Steam, Hot Water



## US, Corn Plus, Winnebago, MN

Start of operation	2005	
Combustion	Concept	
	Fuel	Fluidised Bed Corn Syrup
	Number of Lines	1
	Throughput per line	22.70 t/h
	Thermal power per line	38.00 MW
Flue gas treatment	Concept	Dry Sorption Reactor, Fabric Filter
Energy recovery	Output	Steam



## US, Hampton Roads, VA

Start of operation	2005	
Combustion	Concept	
	Fuel	Fluidised Bed Sewage Sludge
	Number of Lines	1
	Throughput per line	1.10 t/h
	Thermal power per line	2.60 MW
Flue gas treatment	Concept	Scrubber
	Throughput per line	23'000 m³/h (STP)



## CH, Jona

Start of operation	2005	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	330 m³
	Digester Type	ZAFE
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	5'000 t/a



### ES, La Rioja

Start of operation  
Anaerobic Digestion

2005	
Number of Digester(s)	6
Net volume per digester	1'050 m <sup>3</sup>
Digester Type	ZAFB
Waste Type	Organic Fraction of Municipal Solid Waste
Waste Throughput per Year	75'000 t/a



### CH, Lenzburg

Start of operation  
Anaerobic Digestion

2005	
Number of Digester(s)	1
Net volume per digester	340 m <sup>3</sup>
Waste Type	Bio Waste, Food Waste, Green Waste, Liquid Waste
Waste Throughput per Year	5'000 t/a



### MQ, Martinique

Start of operation  
Anaerobic Digestion

2005	
Number of Digester(s)	1
Net volume per digester	750 m <sup>3</sup>
Waste Type	Bio Waste, Green Waste
Waste Throughput per Year	20'000 t/a



### CH, Uzwil 2

Start of operation  
Anaerobic Digestion

2005	
Number of Digester(s)	1
Net volume per digester	1'300 m <sup>3</sup>
Digester Type	ZAFB
Waste Type	Bio Waste, Food Waste, Green Waste, Liquid Waste
Waste Throughput per Year	20'000 t/a



### DE, TREA Breisgau

Start of operation	2004	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	22.00 t/h
	Thermal power per line	61.10 MW
Boiler	Concept	3-pass boiler with external economizer
	Superheated Steam	74 t/h at 40 bar(a) and 400 °C
Flue gas treatment	Concept	Electrostatic Precipitator (2 Fields), SCR, Semi-dry Reactor, Fabric Filter, Scrubber
	Scrubber Reactant	Lye
	Throughput per line	116'000 m³/h (STP)



### JP, Takamatsu, Kagawa Pref.

Start of operation	2004	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	4.17 t/h



### TW, Taitung

Start of operation	2004	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	6.25 t/h
Energy recovery	Output	Electrical Power



### US, MCES, St. Paul, MN

Start of operation	2004	
Combustion	Concept	Fluidised Bed
	Fuel	Sewage Sludge
	Number of Lines	3
	Throughput per line	4.00 t/h
	Thermal power per line	9.40 MW
Flue gas treatment	Concept	SNCR, Fabric Filter, Scrubber
	Scrubber Reactant	Lye
	Throughput per line	40'190 m³/h (STP)
Energy recovery	Output	Steam



### NL, Alkmaar L4

Start of operation	2004	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	27.50 t/h
	Thermal power per line	75.00 MW
Boiler	Concept	4-pass boiler with external economizer
	Superheated Steam	89 t/h at 42 bar(a) and 405 °C
Flue gas treatment	Concept	Electrostatic Precipitator (2 Fields), Electrostatic Precipitator (3 Fields), SCR, Scrubber
	Scrubber Reactant	Caustic Soda
	Reactant	Activated Carbon
	Throughput per line	155'900 m³/h (STP)
Energy recovery	Output	Electrical Power



### JP, Kyoto 1

Start of operation	2004	
Anaerobic Digestion	Number of Digester(s)	2
	Net volume per digester	1'150 m³
	Waste Type	Food Waste, Organic Fraction of Municipal Solid Waste
	Waste Throughput per Year	15'000 t/a



### DE, Passau

Start of operation	2004	
Anaerobic Digestion	Number of Digester(s)	3
	Net volume per digester	980 m³
	Digester Type	ZAFB
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	39'000 t/a



### CH, Thun

Start of operation  
Combustion

Boiler

Flue gas treatment


2003  
Concept  
Fuel

Number of Lines  
Throughput per line  
Thermal power per line  
Concept

Superheated Steam  
Concept

Scrubber Reactant  
Throughput per line

Water-cooled Grate  
Municipal Solid Waste, Sewage  
Sludge  
1  
18.40 t/h  
46.00 MW  
4-pass boiler with external  
economizer  
55 t/h at 40 bar(a) and 400 °C  
Electrostatic Precipitator (3  
Fields), SCR, Ext. Eco, Heat  
Exchanger, Scrubber, Heat  
exchanger again, Fabric Filter, Fly  
Ash Treatment, Dry Sorption  
Reactor  
Lye  
78'000 m³/h (STP)



### FR, Poitiers

Start of operation  
Combustion

2003  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
3.30 t/h



### FR, Evreux

Start of operation  
Combustion

Boiler

Flue gas treatment

Energy recovery


2003  
Concept  
Fuel

Number of Lines  
Throughput per line  
Thermal power per line  
Concept  
Superheated Steam  
Concept

Reactant

Throughput per line  
Concept  
Electric power output  
Output

Air-cooled Grate  
Municipal Solid Waste, Sewage  
Sludge  
2  
5.63 t/h  
14.40 MW  
2-pass boiler  
17 t/h at 40 bar(a) and 380 °C  
Fabric Filter, SCR, Semi-dry  
Reactor, Dry Sorption Reactor  
Lignite Coke, Calcium Hydroxide,  
Sodium Bicarbonate  
31'000 m³/h (STP)  
Back-pressure Turbine  
6.00 MW (gross)  
Electrical Power



### JP, Fukue, Nagasaki Pref

Start of operation	2003	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	
	Number of Lines	2
	Throughput per line	1.20 t/h



### JP, Ishikawahokubu, Ishikawa Pref.

Start of operation	2003	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	
	Number of Lines	2
	Throughput per line	3.33 t/h



### FR, Perpignan

Start of operation	2003	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.10 t/h
	Thermal power per line	32.40 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	35 t/h at 40 bar(a) and 380 °C
Flue gas treatment	Concept	SNCR, Semi-dry Reactor, Fabric Filter
	Throughput per line	61'000 m³/h (STP)
Energy recovery	Concept	Condensation Turbine
	Electric power output	21.00 MW (gross)
	Output	Electrical Power



### JP, Touga, Pref Shizuoka

Start of operation	2003	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	1.88 t/h



### US, WWTP Lynn, MA

Start of operation	2003	
Combustion	Concept	Fluidised Bed
	Fuel	Sewage Sludge
	Number of Lines	1
	Throughput per line	1.07 t/h
	Thermal power per line	2.10 MW
Flue gas treatment	Concept	Scrubber, Electrostatic Precipitator (1 Field)
	Throughput per line	40'100 m³/h (STP)



### CH, Buchs SG L1

Start of operation	2003	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste, Industrial Waste
	Number of Lines	1
	Throughput per line	6.88 t/h
	Thermal power per line	21.80 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	30 t/h at 40 bar(a)
Energy recovery	Output	Steam, Hot Water, Electrical Power



### IT, Bologna

Start of operation	2003	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	13.75 t/h
	Thermal power per line	44.80 MW
Boiler	Concept	4-pass boiler
	Steam	53 t/h at 50 bar(a)



### JP, Niiijima, Tokyo Pref.

Start of operation	2003	
Combustion	Fuel	
	Number of Lines	1
	Throughput per line	1.00 t/h




### CH, Bachenbülach 2

Start of operation	2003	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	340 m <sup>3</sup>
	Waste Type	Bio Waste, Food Waste, Green Waste
	Waste Throughput per Year	10'000 t/a
Gas Upgrading	Technology	Membrane Technology
	Biomethane Usage	Biomethane for gas-grid injection, Combined Heat and Power



### DE, Weissenfels 1

Start of operation	2003	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	980 m <sup>3</sup>
	Digester Type	ZAFB
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	12'500 t/a



### JP, Yachimata II

Start of operation	2003	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.60 t/h



### DE, Bremerhaven Duotherm

Start of operation	2002	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	8.00 t/h
	Thermal power per line	23.30 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	27 t/h at 40 bar(a)
Energy recovery	Output	Electrical Power



### JP, Sakurai, Nara Pref.

Start of operation	2002	
Combustion	Concept	Fluidised Bed Gasification
	Fuel	
	Number of Lines	2
	Throughput per line	3.12 t/h



### FR, Le Mans L2bis

Start of operation	2002	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste, Hospital Waste
	Number of Lines	1
	Throughput per line	9.00 t/h
	Thermal power per line	24.10 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	29 t/h at 30 bar(a) and 350 °C
Flue gas treatment	Concept	Fabric Filter, SCR, Semi-dry Reactor
	Throughput per line	50'000 m³/h (STP)
Energy recovery	Output	Electrical Power



### JP, Nasu, Tochigi Pref.

Start of operation	2002	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.50 t/h
Energy recovery	Output	Steam, Hot Water




### JP, Okinoerabu, Kagoshima Pref.

Start of operation	2002	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	1.00 t/h
Boiler	Concept	Water Injection
	Steam	



### CH, Emmenspitz L4

Start of operation	2002	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste, Industrial Waste, Sewage Sludge
	Number of Lines	1
	Throughput per line	10.00 t/h
	Thermal power per line	28.50 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	32 t/h at 38 bar(a) and 385 °C
Flue gas treatment	Concept	SNCR, Fly Ash Treatment, Scrubber, NH <sub>4</sub> OH-Stripper, Electrostatic Precipitator
	Scrubber Reactant	Lye
	Throughput per line	58'040 m <sup>3</sup> /h (STP)
Energy recovery	Concept	Back-pressure Turbine
	Electric power output	7.70 MW (gross)
	Output	Steam, Hot Water, Electrical Power



### JP, Yamaguchi

Start of operation	2002	
Combustion	Concept	
	Fuel	Fluidised Bed
	Number of Lines	1
	Throughput per line	8.87 t/h
		Industrial Waste, Wood Waste



### JP, Osaka (Maishima)

Start of operation	2001	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	18.75 t/h
Flue gas treatment	Concept	Fabric Filter, Heat Exchanger, SCR, Scrubber
Energy recovery	Output	Electrical Power



### JP, Fukuoka Rinkai

Start of operation	2001	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	12.50 t/h
Energy recovery	Output	Electrical Power



### JP, Nishimurayama, Yamagata Pref.

Start of operation	2001	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	2.08 t/h
Boiler	Concept	Water Injection
	Steam	
Energy recovery	Output	Hot Water



### JP, Tokyo (Chuo)

Start of operation	2001	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	12.50 t/h
	Thermal power per line	15.00 MW
Energy recovery	Output	Hot Water, Electrical Power



### FR, Maubeuge

Start of operation	2001	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	5.50 t/h
	Thermal power per line	14.10 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	17 t/h at 36 bar(a) and 360 °C
Flue gas treatment	Concept	Semi-dry Reactor, Fabric Filter
	Throughput per line	30'500 m³/h (STP)
Energy recovery	Output	Steam, Hot Water, Electrical Power



### FR, Rouen

Start of operation	2001	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	14.50 t/h
	Thermal power per line	38.80 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	46 t/h at 36 bar(a)
Energy recovery	Output	Electrical Power



### FR, Salaise L3

Start of operation	2001	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste, Industrial Waste
	Number of Lines	1
	Throughput per line	19.00 t/h
	Thermal power per line	48.60 MW
Boiler	Concept	3-pass boiler
	Superheated Steam	77 t/h at 42 bar(a) and 350 °C
Flue gas treatment	Concept	
	Throughput per line	140'000 m³/h (STP)
Energy recovery	Output	Steam, Electrical Power



### IT, Trezzo

Start of operation	2001	
Combustion	Concept	
	Fuel	Water-cooled Grate Municipal Solid Waste
	Number of Lines	2
	Throughput per line	16.16 t/h
	Thermal power per line	41.20 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	49 t/h at 40 bar(a) and 400 °C
Energy recovery	Output	Electrical Power



### US, McKay Bay, Tampa, FL

Start of operation	2001	
Combustion	Concept	
	Fuel	Air-cooled Grate Municipal Solid Waste
	Number of Lines	4
	Throughput per line	9.46 t/h
	Thermal power per line	26.30 MW
Boiler	Concept	2-pass boiler
	Steam	24 t/h at 45 bar(a)



### CH, Oetwil am See 1

Start of operation	2001	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	750 m³
	Waste Type	Bio Waste, Food Waste, Green Waste, Liquid Waste
	Waste Throughput per Year	10'000 t/a




### AT, Roppen

Start of operation	2001	
Anaerobic Digestion	Number of Digester(s)	1
	Net volume per digester	750 m <sup>3</sup>
	Waste Type	Bio Waste, Green Waste
	Waste Throughput per Year	10'000 t/a



### DE, Nuremberg L1-L3

Start of operation	2001	
Combustion	Concept	Water-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	10.50 t/h
	Thermal power per line	35.00 MW
Boiler	Concept	4-pass boiler
	Superheated Steam	41 t/h at 45 bar(a) and 400 °C
Flue gas treatment	Concept	Electrostatic Precipitator (3 Fields), SCR, Scrubber
	Scrubber Reactant	Lye
	Throughput per line	64'250 m <sup>3</sup> /h (STP)
Energy recovery	Output	Steam



### JP, Ibaraki III

Start of operation	2001	
Combustion	Concept	Rotary Kiln
	Fuel	Industrial Waste, Refuse Derived Fuel
	Number of Lines	2
	Throughput per line	4.17 t/h



### JP, Minamikawachi-2, Osaka Pref.

Start of operation	2000	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	3.96 t/h
Boiler	Concept	Water Injection
	Steam	



### **KR, Buchon Daejang-Dong**

Start of operation	2000	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	12.50 t/h
Energy recovery	Output	Electrical Power



### **JP, Amagasaki II, Hyogo Pref.**

Start of operation	2000	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	6.25 t/h



### **JP, Hitachi, Ibaraki Pref.**

Start of operation	2000	
Combustion	Concept	Air-cooled Grate
	Fuel	Municipal Solid Waste
	Number of Lines	3
	Throughput per line	4.17 t/h



### **JP, Nishikaigan, Aomori Pref.**

Start of operation	2000	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	1
	Throughput per line	2.75 t/h
Boiler	Concept	Water Injection
	Steam	



### **TW, Hsichou Changhua**

Start of operation	2000	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	18.75 t/h
Energy recovery	Output	Electrical Power




### **TW, Houli Taichung**

Start of operation	2000	
Combustion	Fuel	Municipal Solid Waste
	Number of Lines	2
	Throughput per line	18.75 t/h
Energy recovery	Output	Electrical Power



### **US, Palo Alto, CA**

Start of operation	2000	
Combustion	Concept	Multiple Hearth
	Fuel	Sewage Sludge
	Number of Lines	1
	Throughput per line	1.20 t/h
Flue gas treatment	Concept	Scrubber
	Throughput per line	18'500 m³/h (STP)




### **JP, Chiba II**

Start of operation	2000	
Combustion	Concept	Unknown
	Fuel	Hospital Waste
	Number of Lines	1
	Throughput per line	1.75 t/h
	Thermal power per line	10.17 MW

Plants built by Hitachi Zosen since 2000

**Hitachi Zosen**  
**INOVA**



### **JP, Nankonanbu**

Start of operation  
Combustion

2000  
Concept  
Fuel  
Number of Lines  
Throughput per line

Air-cooled Grate  
Municipal Solid Waste  
2  
1.25 t/h

**Hitachi Zosen Inova AG**

Hardturmstrasse 127  
8005 Zurich  
Switzerland  
P +41 44 277 11 11  
F +41 44 277 13 13  
info@hz-inova.com

**Hitachi Zosen Inova U.S.A. LLC**

10100 Global Way Suite 210  
Knoxville, TN 37932  
United States  
P +1 678 987 25 00  
F +1 678 987 25 99  
info@hz-inova.com

**Hitachi Zosen KRB AG**

Industriestrasse 6  
9470 Buchs/SG  
Switzerland  
P +41 81 750 45 00  
F +41 81 750 45 01  
info-krb@hz-inova.com

**Hitachi Zosen Inova Australia Pty Ltd**

Level 17 40 Mount Street  
North Sydney, NSW 2060  
Australia  
P +61 (02) 8003 4110  
info@hz-inova.com